

CENTRO DI RICERCA E SPERIMENTAZIONE
PER L'INDUSTRIA CERAMICA

Requested by:	CERAMIKA PARADYZ Sp.z.o.o. Ul. Piotrkowska, 61 26-300 Opoczno - POLAND	
For the sample:	Ceramic tiles 59,8 x 59,8 x 0,9 cm marked "MAGNETIK GRES"	
On (date): 24/07/19	Date of receipt in laboratory (sample delivered by the client):	24/07/19
Sampling details	By whom: CUSTOMER	
- Where: -----		
- Date: -----		
- How (methods): -----		
Tested in: Sassuolo	Date of starting: 24/07/2019	Date of ending: 24/07/2019

DIN 51097:1992


Determination of anti – slip properties. Wet-loaded barefoot areas – Walking method – Ramp test

OPERATIVE CONDITIONS:

Size of the tested surface (m): 0,6 x 1,2

Fixing scheme

walking direction



RESULTS

Average slip angle: 20

CLASSIFICATION (BGI/GUV-I 8527 - 2010)

Application range: A+B


Giordana Carani
Technical verification


Prof.ssa Maria Chiara Bignozzi
Director



The results reported relate only to the samples tested. No responsibility is taken for the accuracy of the sampling unless it is done under our own supervision. The reproduction of this test report is only authorized in the form of a complete photographic facsimile. Our written approval is necessary for any partial reproduction. This test report consists of 1 page